

ADDENDUM #3
February 4, 2025
Barrett Mill Water Improvements
Wythe County

Reminder: Bid Opening date is Thursday February 6th, 2025 at the same times and same location.

Bidders must have their

Bidder must have the following in order to have their bid read aloud at the bid opening:

- Addendum acknowledged (currently Addendum #1 and Addendum #2)
- Bid Bond
- Bid form for the appropriate Division completely filled out

Changes to the Contract Documents:

1. Revise the sentence from Paragraph 2.1 A. from Section 11215 – “Water Booster Pump System” to read:

A. ... The system shall be designed to operate on **120/240** volt **single** phase incoming power supply.

Changes to the Plans:

1. Revise the note on C29 at the top of the Single Line Diagram to read:
 - New **120/240 volt, Single Phase**, 60 hz
 - Surge suppressor may be installed within Panelboard “A” (Suppressor to have 50 kA surge current capacity)
2. Revise note 6. On C29 to reflect the Addendum #2 pump requirements

END OF ADDENDUM #3